

Summary Mold Report Lab Results				
Before and After Comparison of Highest Contaminated Area				
<b>Glenwood San Jose, CA</b>	Before (03/27/2012)		After (4/10/2012)	
	Exterior Front	Wall Check, Utility Closet	Exterior Front	Wall Check, Utility Closet
<b>Spore Types Detected (per m3)</b>				
Basidiospores	1,900	2,100	2900	-
Chaetomium	-	1,600	13	-
Cladosporium	270	-	110	-
Penicillium/Aspergillus types	160	280,000	1200	-
Stachybotrys	-	4,500	-	67
Hypal fragments	13	130	13	-
Others	1,000	470	880	-
<b>Total:</b>	<b>3,343</b>	<b>288,800</b>	<b>5116</b>	<b>67</b>
<b>Cherry St, San Carlos, CA</b>	Before (03/27/2012)		After (4/10/2012)	
	Exterior Front	Wall Check at Bath	Exterior Front	Wall Check at Bath
<b>Spore Types Detected (per m3)</b>				
Basidiospores	2100	5000	640	530
Chaetomium		130		
Cladosporium	800	23000	750	800
Penicillium/Aspergillus types	590	12,000	1200	270
Hypal fragments	-	1800	40	67
Others	800	8,500	670	530
<b>Total:</b>	<b>4,290</b>	<b>50,430</b>	<b>3300</b>	<b>2197</b>
<b>Ashbury St. San Francisco, CA</b>	Before (03/16/2012)		After (03/20/2012)	
	Exterior Front	1st. Floor Wall Check Closet	Exterior Front	1st. Floor Wall Check Closet
<b>Spore Types Detected (per m3)</b>				
Basidiospores	3000	800	4400	430
Chaetomium	-	27	-	-
Cladosporium	110	1000	480	-
Penicillium/Aspergillus types	210	370	480	110
Hypal fragments	-	130	80	-
Others	930	370	960	160
<b>Total:</b>	<b>4250</b>	<b>2697</b>	<b>6320</b>	<b>700</b>
<b>Molton Ave. San Carlos, CA</b>	Before (06/13/2012)		After (06/21/2012)	
	Exterior Front	Wall Check Vanity	Exterior Front	Wall Check Vanity
<b>Spore Types Detected (per m3)</b>				
Basidiospores	1,900		53	
Chaetomium		67		-
Cladosporium	960		910	
Penicillium/Aspergillus types	1,200	120,000		-
Stachybotrys		900,000		-
Hyphal fragments	40	95,000	80	-
Others	950		93	
§ Total:	5,050	1,115,067	1,136	<67
<b>Ashbury St. San Francisco, CA</b>	Before (07/05/2012)		After (7/06/2012)	
	Exterior Front	1st. Floor Wall Check Closet	Exterior Front	1st. Floor Wall Check Closet
<b>Spore Types Detected (per m3)</b>				
Basidiospores	590	-	110	-
Cladosporium	4800	-	5100	-
Penicillium/Aspergillus types	370	700,000	430	800
Hyphal fragments	40	8900	80	-
Others	870	67	640	67
§ Total:	6,670	708,967	6,360	867
<b>Burning Tree. Half Moon Bay, CA</b>	Before (07/13/2012)		After (07/18/2012)	
	Exterior Front	Family Room - Wall Check	Exterior Front	Family Room - Wall Check
<b>Spore Types Detected (per m3)</b>				
Basidiospores		530	210	-
Chaetomium		530		-
Cladosporium	480	-	850	-
Penicillium/Aspergillus types	210	3,300	530	-
Stachybotrys		10,000		-
Hyphal fragments	40	1,200	27	-
Others	150	130	190	-
§ Total:	880	15,690	1,807	0
Limit of Detection - 13 exterior, 67 interior				
Sample volumes in liters - 75 exterior, 15 interior				



